



SCESp 008

S SCHWEIZERISCHER ZERTIFIZIERUNGSDIENST
 CE SERVICE SUISSE DE CERTIFICATION
 Sp SERVIZIO SVIZZERO DI CERTIFICAZIONE
 SWISS CERTIFICATION SERVICE



suvaPro
 CERTIFICATION

Type-examination certificate no. E 6079/2.e

Object: contactor relay

Make: Sprecher+Schuh

Type designation: CS7-... E; CS7D-... E; CS7C-... E contactor relays
 CS7-PV-...; CA7-PV-...; CA7-PV-S... auxiliary switches, front-mounted
 CA7-PA-...; CA7-PA-S... auxiliary switches, side-mounted

Technical details concerning safety: mechanically linked contacts
 (positively driven contacts, forced contacts, forcibly guided contacts)
 according to IEC 60947-5-1, Annex L

Manufacturer's address: Rockwell Automation AG
 Buchserstrasse 7
 CH-5000 Aarau

Address of applicant: Rockwell Automation AG
 Buchserstrasse 7
 CH-5000 Aarau

Special conditions, enclosures: see supplementary sheet 1/1

Expires on: 28 December 2009

The prototype tested satisfies the current relevant provisions of Directive 98/37/EC (formerly Council Directive 89/392/EEC and its amendments) of the European Parliament and of the Council on the approximation of the laws of the Member States relating to machinery.

This certificate is valid in conjunction with the general provisions listed on the reverse and any previously mentioned enclosures.

European notified body, identification number 1246

Place and date:
 Lucerne, 27 June 2008

Suva
 Accredited Certification Body SCESp 008
 Technology Sector

The Safety Engineer
 Peter Kocher

Head of Certification
 Guido Schmitter

Peter Kocher

Guido Schmitter



S SCHWEIZERISCHER ZERTIFIZIERUNGSDIENST
CE SERVICE SUISSE DE CERTIFICATION
Sp SERVIZIO SVIZZERO DI CERTIFICAZIONE
S SWISS CERTIFICATION SERVICE

SCESp 008



suvaPro
CERTIFICATION

Supplementary sheet to Certificate no. E 6079/2.e

Lucerne, 27 June 2008

The type-examination certificate is valid for the following types:

contactor relays with AC-coil:

CS7-40E CS7-31E CS7-22E CS7-13E CS7-04E

contactor relays with DC-coil and surge suppressor:

CS7D-40E CS7D-31E CS7D-22E CS7D-13E CS7D-04E

contactor relays with DC-coil:

CS7C-40E CS7C-31E CS7C-22E CS7C-13E CS7C-04E

auxiliary switches, front-mounted:

CS7-PV-02 CA7-PV-02
CS7-PV-11 CA7-PV-11
CS7-PV-20 CA7-PV-20
CS7-PV-04 CA7-PV-22
CS7-PV-13
CS7-PV-22 CA7-PV-S11
CS7-PV-31 CA7-PV-S22
CS7-PV-40 CA7-PV-S31

auxiliary switches, side-mounted:

CA7-PA-01 CA7-PA-S01
CA7-PA-02 CA7-PA-S02
CA7-PA-10 CA7-PA-S10
CA7-PA-11 CA7-PA-S11
CA7-PA-20 CA7-PA-S20

Appendix

Last page of the supplementary sheet to Certificate no. E 6079/2.e.