



**SHUNT TRIP
 DÉCLENCHEUR SHUNT
 ARBEITSSTROMAUSLÖSER
 SGANCIATORE DI APERTURA
 CONMUTADOR REMOTO**
 (Cat L9-ASTA1, -ASTA2)




ATTENTION: To prevent electrical shock, disconnect from power source before installing or servicing.

ATTENTION: Avant le montage et la mise en service, couper l'alimentation secteur pour éviter toutes décharges.







ACHTUNG: Vor Installations- oder Servicearbeiten Stromversorgung unterbrechen, um Elektroschocks zu vermeiden.

ATTENZIONE: Per prevenire infortuni, togliere tensione prima dell'installazione o manutenzione.


ATENCIÓN: Desconéctese de la corriente eléctrica, antes de la instalación o del servicio, a fin de impedir sacudidas eléctricas.



L9-AST ...

	Cu  only mm ²	AWG		  	
L9-AST ...	1 x 1 - 6	1 x #18 - #10	12 mm (.50")	Z2	1.0 x 6.5mm (.040 x .25 in)
	2 x 1 - 2 x 6	2 x #18 - 2 x #10			

Allowable Combinations and Positions
Combinazioni et Positions Possible
Zulaessige Kombinationen und Positionen
Combinazioni e Posizioni Accettabili
Combinaciones y Posiciones Válidas



Maximum
 Massimo
 Máximo

LX- AHS3	L9- AST. . .	L9-Circuit Breaker
X		X
	X	X
X	X	X

L9- . . . + L9-AST . . .

