

## *Australian Declaration of Conformity*

*The undersigned, representing the Manufacturer:*  
**Sprecher + Schuh, Inc.**  
**15910 International Plaza Drive**  
**Houston, TX 77032**  
**USA**

**Supplier Number (ERAC): E519**

*and the Authorised Supplier within Australia:*  
**Rockwell Automation Australia Ltd.**  
**841 Mountain Highway**  
**Bayswater, Vic. 3153**  
**Australia**

**Australian Business Number (ABN): 80005549477**

---

*Herewith declare that the Products:*      **Sprecher + Schuh CEP7-1 Series (3<sup>rd</sup> Generation)**

*Product identification:*                      *(reference the attached list of catalogue numbers)*

---

*are in conformity with the following when installed in accordance with the installation instructions contained in the product documentation:*

*Radiocommunications Act:1992 (including Amendments up to 2018)*

*Radiocommunications (Electromagnetic Compatibility) Standard 2017*

*Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017*

---

*and that the standards and/or technical specifications referenced below have been applied:*

*EN 60947-4-1:2010 + A1:2012*                      *Low-voltage switchgear and controlgear – Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters*

---

*Compliance Folder is maintained at:*      *Rockwell Automation Australia Ltd.*  
*841 Mountain Highway*  
*Bayswater, Vic. 3153*  
*Australia*

*Document No.:*                                      *AUS-0641-EN*

---

*Signed for and on behalf of the above named Manufacturer:*

*Place and date of issue:*                      *Milwaukee, WI USA*                                      *02-Nov-2021*

*Name, function:*                                      *Daniel L. Nachtigall, Technical Leader – Product Compliance Engineering*

*Signature:*

*Daniel L. Nachtigall*

---

<i>Catalogue number</i>	<i>Description</i>
CEP7-1EExx	<i>Single &amp; three-phase adjustable overload relay per Nomenclature</i>
CEP7-1EFxx	<i>Single &amp; three-phase adjustable overload relay per Nomenclature</i>
<b>Accessories</b>	
CEP7-1EGJ	<i>Universal protection module (ground fault/jam)</i>
CEP7-1ERR	<i>Reset adapter (electronic remote reset)</i>
CEP7-1ERIDN	<i>Remote indication display module</i>

NOMENCLATURE:

CEP7	-	EE	A	B
1		2	3	4

1	Product Line CEP7 – IEC overload relay, three-phase, with screw clamp control terminals
2	Designates Relay Type 1EE – Adjustable trip solid state overload relay; Class 10, 20; manual reset 1EF – Adjustable trip solid state overload relay; Class 10, 15, 20, 30; manual or automatic reset
3	Designates Current Range A – 0.1...0.5A                      H – 30...150A (150:5 CT) B – 0.2...1.0A                      J – 40...200A (200:5 CT) C – 1.0...5A                         K – 60...300A (300:5 CT) D – 3.2...16A                        L – 100...500A (500:5 CT) E – 5.4...27A                        M – 120...600A (600:5 CT) F – 11...55A                         N – 160...800A (800:5 CT) G – 20...100A                        W – 80...400A (400:5 CT)
4	Designates Contactor Size B – CA7-9 to CA7-23 D – CA7-30 to CA7-55 E – CA7-60 to CA7-97 P – Pass-thru Design Z – For use with external CT