

EC Declaration of Conformity

and the authorised representative established within the The undersigned, representing the manufacturer

Community

Sprecher + Schuh

15910 International Plaza Drive

Houston, TX 77032

U.S.A.

Rockwell Automation BV Rivium 1e Straat, 23

2909 LE Capelle aan den IJssel

Netherlands

herewith declare that the Products **Busbars for IEC Circuit Breakers**

Product identification (brand and catalogue number/part number):

Sprecher + Schuh L9-AACL Series (see attached list of catalogue numbers)

are in conformity with the essential requirements of the following EC Directive(s) when installed in accordance with the installation instructions contained in the product documentation:

2006/95/EC Low Voltage Directive

and that the standards and/or technical specifications referenced below have been applied:

EN 60947-1:2007 Low-voltage switchgear and controlgear assemblies – Part 1: General rules

EN 60439-1:1999 + A1:2004 Low-voltage switchgear and controlgear assemblies - Part 1: Type-tested and

partially type-tested assemblies

EN 60439-2:2000 + A1:2005 Low-voltage switchgear and controlgear assemblies – Part 2: Particular

requirements for busbar trunking systems (busways)

EN 60439-3:1991 + A1:1994 +

A2:2001

Low-voltage switchgear and controlgear assemblies – Part 3: Particular requirements for low-voltage switchgear and controlgear assemblies intended to be installed in places where unskilled persons have access for their use –

Distribution boards

Year of CE Marking (Low Voltage Directive):

ain h. hachtigall

2010

Manufacturer:

Authorised Representative in the Community:

non- Shill

Signature

Date:

Name: Daniel L. Nachtigall

Position: Supv – Product Certification Engineering

18-Feb-2011

Signature

Name: Viktor Schiffer Position: **Engineering Manager**

22-Feb-2011 Date:

sprecher+ schuh

Catalogue number	Description
L9-AACL106	Busbar for a maximum of six, one pole circuit breakers
L9-AACL112	Busbar for a maximum of twelve, one pole circuit breakers
L9-AACL118	Busbar for a maximum of eighteen, one pole circuit breakers
L9-AACL206	Busbar for a maximum of three, two pole circuit breakers
L9-AACL212	Busbar for a maximum of six, two pole circuit breakers
L9-AACL218	Busbar for a maximum of nine, two pole circuit breakers
L9-AACL306	Busbar for a maximum of two, three pole circuit breakers
L9-AACL312	Busbar for a maximum of four, three pole circuit breakers
L9-AACL318	Busbar for a maximum of six, three pole circuit breakers