



Type-examination certificate no. E 6396/3.e

Object:	contactor relay
Mark:	Sprecher + Schuh
Type designation:	CSS7- . . E*; CSS7C- . . E*; CSS7D- . . E*; CSS7E- . . E* contactor relays CSS7-PV*; CAS7-PV* auxiliary switches, front-mounted
Technical details concerning safety:	The product meets the requirements of IEC /EN 60947-5-1, including Annex L
Manufacturer's address:	Rockwell Automation Switzerland GmbH Industriestrasse 20 CH-5000 Aarau
Address of applicant:	Rockwell Automation Switzerland GmbH Industriestrasse 20 CH-5000 Aarau
Special conditions, enclosures:	See supplementary sheet 1/1
Expires on:	28 February 2023

The prototype examined corresponds to the essential requirements of Directive 2014/35/EU and the amendments of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits.
This certificate is valid in conjunction with the general conditions listed on the back and any possible enclosures mentioned above.

Place and date:
Lucerne, 7 February 2018

Suva
Accredited Certification Body SCESp 0008
Technology Sector

The Safety Engineer
Peter Kocher

Head of Certification
Guido Schmitter



The type-examination certificate is valid for the following types:

Contactor relays with AC-coil:

CSS7-44E* CSS7-53E* CSS7-62E* CSS7-35E*

Contactor relays with DC-coil:

CSS7C-44E* CSS7C-53E* CSS7C-62E* CSS7C-35E*

Contactor relays with DC-coil and surge suppressor:

CSS7D-44E* CSS7D-53E* CSS7D-62E* CSS7D-35E*

Contactor relays with electronically controlled DC-coil:

CSS7E-44E* CSS7E-53E* CSS7E-62E* CSS7E-35E*

Auxiliary switches, front-mounted:

CSS7-PV* CAS7-PV*

In context with this type-examination certificate the meaning of the term mechanically linked contacts is as follows:

If any NO contact is closed, none of the NC contacts is closed.

If any NC contact is closed, none of the NO contacts is closed.

(IEC 60947-5-1, Annex L)

The use of type S devices containing irremovably mounted auxiliary switches ensures that all contacts of the complete device are mechanically linked.

In order to prevent manual operation in safety-relevant parts of control systems, protective covers have to be used.

General conditions

This certificate is valid for the product or product category bearing the trademark and type shown on the front page. In order to guarantee its compliance with the essential health and safety requirements of Directive 2006/42/EC for machines or Directive 89/686/EEC for personal protective equipment or Directive 2014/35/EU for low voltage equipment, each product or product category must be marked in accordance with the requirements of the directive given on the front page and its amendments.

Under the trademark and type designation stated on the front page, the manufacturer or supplier undertakes to deliver only products which, in all aspects that may influence their safety, satisfy the prerequisites for this certificate exactly. This certificate automatically becomes invalid if this condition is not fulfilled.

When assessing the product or product category stated on the front page, it has been assumed that its design and manufacture correspond to the recognized state of the art.

With regard to the operating and servicing instructions supplied with the product, we refer to the requirements of the Directive stated on the front page.

If organizational measures are required to guarantee safety, they must be made known to the buyer and the user and included in the operating and servicing instructions.

The manufacturer is obliged to report to the certification body any complaints regarding the product or product category described on the front page as well as the remedying of faults without delay.

With regard to the area of application, placing on the market and putting into service, free passage of goods, conformity assessment procedures and CE marking, the conditions of the Directive stated on the front page must be complied with.

Reference to this certificate in quotations, brochures, advertisements or other publicity media may only be made if accompanied by its number.

Upon request, the term of validity of the certificate is extended if the product or product category with the relevant conditions of use continues to fulfil the applicable health and safety requirements.

However, if new experience or findings indicate that adequate safety cannot be guaranteed or if the product or product category no longer corresponds to the latest state of the art, the certificate can be cancelled by Suva's certification body at any time.

Certification Body SCESp 0008; European notified body, identification number 1246

Suva, Technology Sector, P.O. Box 4358, CH-6002 Lucerne
Phone + 41 (0) 41 419 61 31, Fax + 41 (0) 41 419 58 70
www.suva.ch/certification-e