

强制性认证产品符合性自我声明



自我声明编号: 2021000307000494

Rockwell Automation, Inc. (生产者) 及 罗克韦尔自动化(中国)有限公司(生产者授权代表) 确认知晓《强制性产品认证自我声明实施规则》以及相关产品强制性认证实施规则的要求, 对本声明承担全部法律责任。

Rockwell Automation, Inc. (生产者) 及 罗克韦尔自动化(中国)有限公司(生产者授权代表) 声明以下产品已按照《强制性产品认证自我声明实施规则》以及相关产品强制性认证实施规则的要求进行检测, 符合相关标准要求; 自本声明签署之日起, 生产和销售的产品持续符合以下标准与实施规则的要求; 保存本声明涉及的技术文档至少10年; 正确使用强制性产品认证标志; 如产品或其符合性信息发生变更, 将及时更新技术文档并报送产品变更信息。

生产者名称: Rockwell Automation, Inc.
生产者地址: 1201 South Second Street, Milwaukee, WI 53204, USA
依据的强制性产品认证规则: CNCA-00C-008: 2019 强制性产品认证实施规则自我声明
产品名称: 塑料外壳式断路器
产品系列、型号、规格: 140UT-D7..., KTU9-40H...; 型号规格详见附录
依据的标准: GB/T 14048.2-2020

序号	生产企业名称	生产企业地址
1	Rockwell Automation Sp. z.o.o	UL. Rozdzienska 49, 40-382 Katowice, Poland
2	Rockwell Automation, Inc., Ladysmith	1506 East 16th Street South, Ladysmith, WI54848, USA
3	Rockwell Automation, B.V., Best Configuration Center	Brem 5, 5684 PB, Best, The Netherlands

生产者联系信息

名称: Rockwell Automation, Inc.
地址: 1201 South Second Street, Milwaukee, WI 53204, USA
联系人: 潘亮
电话: 021-61288888
电子邮箱: llpan@ra.rockwell.com
自我声明时间: 2021-07-15
自我声明地点: 上海
指定签字人: 潘亮
签章: 潘亮

授权代表信息

名称: 罗克韦尔自动化(中国)有限公司
地址: 上海市徐汇区虹梅路1801号宏业大厦
联系人: 潘亮
电话: 021-61288888
电子邮箱: llpan@ra.rockwell.com
自我声明时间: 2021-07-15
自我声明地点: 上海
指定签字人: 潘亮
签章: 潘亮

注: 有关本声明信息真伪可登录全国认证认可信息公共服务平台 (cx.cnca.cn) 或扫描右上角二维码查询。

附录(Appendix):

第1页共5页 (Page 1 of 5)

自我声明编号(CCC DoC No.): 2021000307000494

有效期(Period of Validity): 2021/07/15 – 2031/07/14

1. 基本信息(Basic Information):

生产者 (制造商)
(Manufacturer): Rockwell Automation, Inc.

生产者地址
(Address): 1201 South Second Street, Milwaukee, WI 53204, USA

生产企业
(Factory): 见生产厂一览表 Refer to list of factories

生产企业地址
(Address): 见生产厂一览表 Refer to list of factories

产品名称
(Product Name): 塑料外壳式断路器 Molded Case Circuit Breaker

型号
(Product Model/Type): 140UT-D7..., KTU9-40H...;

适用标准
(Standards): GB/T 14048.2-2020

自我声明时间
(Date of Submission): 2021/07/15

备注(Note): 产品认证咨询请邮件联系(For consultation on product certification, please send e-mail to): productcertification@ra.rockwell.com

生产企业一览表(List of Factories): 适用时(If Applicable)

序号 (No.)	生产企业 (Name of Factory)	生产企业地址 (Address)	生产企业代码 (Factory Code)
1	Rockwell Automation Sp. z.o.o	UL. Rozdzienska 49, 40-382 Katowice, Poland	1170/1270
2	Rockwell Automation, Inc., Ladysmith	1506 East 16th Street South, Ladysmith, WI54848, USA	1080
3	Rockwell Automation, B.V., Best Configuration Center	Brem 5, 5684 PB, Best, The Netherlands	4010

注: 此附录与自我声明同时使用时有效。

Note: The appendix is valid when used together with corresponding CCC DoC.

附录(Appendix):

第2页 共5页 (Page 2 of 5)

自我声明编号(CCC DoC No.): 2021000307000494

有效期(Period of Validity): 2021/07/15 – 2031/07/14

2. 规格参数(Specification):

140UT-D7..., KTU9-40H...

Ui:690V;Uimp:6kV;

Ue: AC230/240V,400/415V,500/525V,690V;

In: 0.5A,1A,2A,3A,4A,5A,6A,8A,10A,12A,15A,20A,25A,30A,35A,40A;

140UT-D7D2-...,KTU9-40H-2D-...

Ics: AC230/240V: 100kA;

AC400/415V:65kA(0.5A,1A,2A,3A,4A,5A,6A,8A,10A),50kA(12A,15A,20A,25A,30A,35A,40A);

AC500/525V: 65kA(0.5A,1A,2A,3A,4A,5A,6A,8A,10A), 50kA(12A,15A,20A),

25kA(25A,30A,35A,40A);

AC690V:50kA(0.5A,1A), 10kA(2A,3A,4A,5A,6A), 6kA(8A,10A,12A,15A,20A,25A,30A,35A,40A);

Icu: AC230/240V:100kA;

AC400/415V:100kA(0.5A,1A,2A,3A,4A,5A,6A,8A,10A),:65kA(12A,15A,20A,25A,30A,35A,40A);

AC500/525V: 65kA;

AC690V:50kA(0.5A,1A), 18kA(2A,3A,4A,5A,6A),10kA(8A,10A,12A,15A,20A,25A,30A,35A,40A);

140UT-D7D3-...,KTU9-40H-3D-...

Ics: AC230/240V:100kA;

AC400/415V:65kA(0.5A,1A,2A,3A,4A,5A,6A,8A,10A),50kA(12A,15A,20A,25A,30A,35A,40A);

AC500/525V:65kA(0.5A,1A,2A,3A,4A,5A,6A,8A,10A),50kA(12A,15A,20A),

25kA(25A,30A,35A,40A);

AC690V:50kA(0.5A,1A), 10kA(2A,3A,4A,5A,6A), 6kA(8A,10A,12A,15A,20A,25A,30A,35A,40A)

Icu: AC230/240V:100kA;

AC400/415V:100kA(0.5A,1A,2A,3A,4A,5A,6A,8A,10A),65kA(12A,15A,20A,25A,30A,35A,40A);

AC500/525V: 65kA;

AC690V:50kA(0.5A,1A), 18kA(2A,3A,4A,5A,6A),10kA(8A,10A,12A,15A,20A,25A,30A,35A,40A);

过电流脱扣器类型 Over-current Release Type:热磁式 Thermal Magnetic;

选择性类别 Selectivity Category:A;

适用频率 Frequency: 50/60Hz

极数 Poles:2P,3P;

适用于隔离 Suitable for insulation;

配用的辅助触头 Auxiliary Circuits:

Ith: 5A (40°C) front mounting; 10A (40°C) side mounting;

Ui: 415V (front mounting), 690V (side mounting);

Uimp: 4kV (front mounting), 6kV (side mounting);

种类和对数 Kind of contact elements and number of auxiliary circuits: NO, NC, NO+NO, NC+NC or NO+NC, 1- or 2-poles;

Front Mounting: Ue/Ie: AC-12:415V/5A;

注: 此附录与自我声明同时使用时有效。

Note: The appendix is valid when used together with corresponding CCC DoC.

附录(Appendix):

第3页 共5页 (Page 3 of 5)

自我声明编号(CCC DoC No.): 2021000307000494

有效期(Period of Validity): 2021/07/15 – 2031/07/14

AC-15: 24V/4A, 120V/3A, 240V/1.5A, 415V/0.9A;

DC-13: 24V/1.2A, 125V/0.22A, 250V/0.11A;

Right-side Mounting: Ue/Ie: AC-12: 690V/10A;

AC-15: 24V/6A, 120V/6A, 240V/3A, 415V/2A, 500V/1.5A, 690V/1.2A;

DC-13: 24V/2A, 125V/0.55A, 250V/0.27A, 415V/0.15A, 500V/0.13A,
600V/0.1A.

注: 此附录与自我声明同时使用时有效。

Note: The appendix is valid when used together with corresponding CCC DoC.

附录(Appendix):

第4页共5页 (Page 4 of 5)

自我声明编号(CCC DoC No.): 2021000307000494

有效期(Period of Validity): 2021/07/15 – 2031/07/14

3. 型号的解释(Explanation of Catalog No.):

Allen-Bradley Catalog explanation:

140UT	-	D7	D2	-	A50	-	MT
1		2	3		4		5

1	140UT: Motor Protection Circuit Breakers		
2	D7: Frame High breaking capacity		
3	D2: 2-Pole D3: 3-Pole		
4	Rated Operational Current Ie (A)		
	A50 = 0.5A	B10 = 1.0A	C10 = 10A
		B20 = 2.0A	C12 = 12A
		B30 = 3.0A	C15 = 15A
		B40 = 4.0A	C20 = 20A
		B50 = 5.0A	C25 = 25A
		B60 = 6.0A	C30 = 30A
		B80 = 8.0A	C35 = 35A
			C40 = 40A
5	Customer convenience options – Miscellaneous		
	No Suffix	No Option	
	MT	Standard Bus Bar mount (top feed)	
	MC	Compact Bus Bar mount (top feed)	

Note:

* All the customer convenience options (5) are only for convenience of the customer, they do not sever for the standard products, and all these options can be done by the customer themselves, and they are not printed on the nameplate for the standard devices.

Sprecher + Schuh Catalog explanation:

KTU9	-	40H	-	2D	-	0.5A
1		2		3		4

1	KTU9: Motor Protection Circuit Breakers					
2	40H: Frame 40H High breaking capacity					
3	D2: 2-Pole D3: 3-Pole					
4	Rated Operational Current Ie (A)					
	0.5A = 0.5A	1A = 1.0A		10A = 10A		
		2A = 2.0A		12A = 12A		
		3A = 3.0A		15A = 15A		
		4A = 4.0A		20A = 20A		
		5A = 5.0A		25A = 25A		
		6A = 6.0A		30A = 30A		
		8A = 8.0A		35A = 35A		
				40A = 40A		

注：此附录与自我声明同时使用时有效。

Note: The appendix is valid when used together with corresponding CCC DoC.

附录(Appendix):

第5 页 共5 页 (Page 5 of 5)

自我声明编号(CCC DoC No.): 2021000307000494

有效期(Period of Validity): 2021/07/15 – 2031/07/14

NOTE:

1. The catalog breakdown only demonstrates standard options, any more customized options can be covered if its electrical specification are same as the standard options.
2. The plant code is 1170/1270, 1080, 4010 in Rockwell Automation's SAP system.

注: 此附录与自我声明同时使用时有效。

Note: The appendix is valid when used together with corresponding CCC DoC.