

EU Declaration of Conformity

Product: <i>IEC Circuit Breakers and Accessories</i>	
<i>Name and address of the manufacturer:</i> Sprecher + Schuh 15910 International Plaza Drive Houston, TX 77032 U.S.A.	<i>Name and address of the authorised representative:</i> Rockwell Automation NV Pegasus Park De Kleetlaan 12A 1831 Diegem Belgium
<i>This declaration of conformity is issued under the sole responsibility of the manufacturer.</i>	
<i>Object of the declaration:</i>	Sprecher + Schuh KTU9 and Accessories (reference the attached list of catalogue numbers)
<i>The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:</i>	
2014/35/EU	Low Voltage Directive (LVD)
2011/65/EU	RoHS Directive (RoHS)
<i>References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:</i>	
EN 60947-2:2017+A1:2020	Low-voltage switchgear and controlgear – Part 2: Circuit Breakers
EN 60947-4-1:2010+A1:2012	Low-voltage switchgear and controlgear – Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters
EN IEC 63000:2018	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances
<i>Signed for and on behalf of the above named manufacturer:</i>	
<i>Place and date of issue:</i>	Aarau, Switzerland 09-Jul-2021
<i>Name, function:</i>	Daniel Baumann, Manager-Product Compliance Engineering
<i>Signature:</i>	i.V. <u><i>Daniel Baumann</i></u>

<i>Catalogue number</i>	<i>Series ¹</i>	<i>Description</i>	<i>Directive ²</i>	
			<i>LVD</i>	<i>RoHS</i>
KTU9-*-*-*		<i>Molded Case Circuit Breakers per Nomenclature</i>	<i>Yes</i>	<i>Yes</i>
<i>Accessories</i>				
KTU9-D-DB*-*-*		<i>Compact Busbars 64A per Nomenclature</i>	<i>N/R</i>	<i>Yes</i>
KTU9-D-A3E		<i>Feeder Terminal 64A</i>	<i>N/R</i>	<i>Yes</i>
KTU9-D-PEC23		<i>Eco Connecting Module 32A</i>	<i>N/R</i>	<i>Yes</i>

1) If no series number is given, then all series are covered.

2) Yes = Product is certified to this directive.

N/R = This directive is not required for this product.

MODEL NOMENCLATURE:
Molded Case Circuit Breakers Catalogue Number Explanation

KTU9	-	40H	-	2D	-	0.5
1		2		3		4

<i>Position</i>	<i>Catalogue No. Suffix</i>	<i>Options/Descriptions</i>
<i>1</i>	<i>KTU9</i>	<i>Base Catalogue Number Molded Case Circuit Breaker (UL 489)</i>
<i>2</i>	<i>40H</i>	<i>Frame Size Frame Size D</i>
<i>3</i>	<i>2D 3D</i>	<i>Function Fix Thermal / Fix Magnetic (15...20xIn), 2 poles Fix Thermal / Fix Magnetic (15...20xIn), 3 poles</i>
<i>4</i>	<i>0.5 1 2 3 4 5 6 8 10 12 15 20 25 30 35 40</i>	<i>Code for Current Range 0.5A 1A 2A 3A 4A 5A 6A 8A 10A 12A 15A 20A 25A 30A 35A 40A</i>

Accessories Catalogue Number Explanation

Compact Busbars 64A

KTU9-D-DB	45	-	2
1	2		3

<i>Position</i>	<i>Catalogue No. Suffix</i>	<i>Options/Descriptions</i>
<i>1</i>	<i>KTU9-D-DB</i>	<i>Base Catalogue Number of Compact Busbar 64A</i>
<i>2</i>	<i>45</i>	<i>Distance between sets of prongs 45 mm</i>
<i>3</i>		<i>Number of sets of prongs</i>
	<i>2</i>	<i>2 sets of prongs</i>
	<i>3</i>	<i>3 sets of prongs</i>
	<i>4</i>	<i>4 sets of prongs</i>
	<i>5</i>	<i>5 sets of prongs</i>