

EC Declaration of Conformity

Issued by:

Wöhner GmbH & Co. KG
Mönchrödener Str. 10, 96472 Rödental, Germany

Product designation:

Switch-disconnector for fuses 10x38, 14x51 and 22x58
Disconnectors for fuses 8x31

The above mentioned products conform with the basic safety requirements of the following European Regulation:

Number: 2006/95/EC

Text: Directive on the harmonisation of the laws of Member States relating to Electrical Equipment designed for use within certain voltage limits

The conformity is approved by the application of the following standards:

Harmonized European standards:

EN 60947-1:2007
EN 60947-3:2009

IEC standards:

IEC 60947-1:2007
IEC 60947-3:2008

Nationale Normen:

DIN EN 60947-1/04.08
DIN EN 60947-3/02.10

CE marking since: 1996




Alex Büttner
Geschäftsführer


ppa. Holger Schulte
Leiter Vertrieb Inland

Please note:

This certificate refers to the production status of the mentioned products at the time of issue. It is based on a design evaluation respecting the valid standards. It is also based on our experience with similar products. The rated values are valid for one single device in free air. In accordance with the exact application conditions, system-dependent reduction factors shall be provided. For the use of our products DIN EN 60439-1 is to be applied in the currently valid version. Furthermore, the indications in our product manual are to be observed. A test regarding the exact conditions of use would need to be ordered specially. This certificate will not be updated after future changes in design or technology.

EG-Konformitätserklärung

Aussteller:

Wöhner GmbH & Co. KG
Mönchrödener Str. 10, 96472 Rödental, Germany

Produktbezeichnung:

Lasttrennschalter für Sicherungen 10x38, 14x51 und 22x58
Trennschalter für Sicherungen 8x31

Die oben benannten Produkte stimmen mit den grundlegenden Sicherheitsanforderungen der folgenden Europäischen Richtlinie überein:

Nummer: 2006/95/EG

Text: Richtlinie zur Angleichung der Rechtsvorschriften der Mitgliedstaaten betreffend elektrische Betriebsmittel zur Verwendung innerhalb bestimmter Spannungsgrenzen.

Die Übereinstimmung ist nachgewiesen durch die Anwendung folgender Normen:

Harmonisierte Europäische Normen:

EN 60947-1:2007
EN 60947-3:2009

IEC-Standards:

IEC 60947-1:2007
IEC 60947-3:2008


Nationale Normen:

DIN EN 60947-1/04.08
DIN EN 60947-3/02.10

CE-Kennzeichnung seit: 1996

 TL
Wöhner
Test Laboratory

Rödental, 14.06.2012


Alex Büttner
Geschäftsführer


ppa. Holger Schulte
Leiter Vertrieb Inland

Bitte beachten Sie:

Diese Bestätigung bezieht sich auf den Fertigungsstand der angegebenen Produkte zum Zeitpunkt der Ausstellung. Sie basiert auf einer konstruktiven Beurteilung unter Zuhilfenahme der gültigen Standards und unserer Erfahrung mit vergleichbaren Produkten. Die Bemessungswerte gelten jeweils für ein Einzelgerät in freier Luft. Entsprechend den konkreten Einsatzbedingungen sind anlagenspezifische Reduktionsfaktoren vorzusehen. Für die Anwendung unserer Produkte gilt die DIN EN 60439-1 in der jeweils gültigen Ausgabe. Ferner sind die Angaben in unserem Produkthandbuch zu berücksichtigen. Eine Prüfung entsprechend konkreter Einsatzbedingungen wäre gesondert zu beauftragen. Bei künftigen konstruktiven oder technologischen Änderungen wird diese Bestätigung nicht aktualisiert.