UK Declaration of Conformity

Product:	***Enclosed IEC Direct-On-Line Contactors***

Name and address of the manufacturer: ***Rockwell Automation Inc.*** ***1201 South 2nd Street*** ***Milwaukee, WI 53204*** ***U.S.A.***	*Name and address of the authorised representative:* ***Rockwell Automation Ltd.*** ***Pitfield*** ***Kiln Farm*** ***Milton Keynes*** ***MK11 3DR***

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Object of the declaration:	***Sprecher + Schuh CAT8N Series*** *(reference the attached list of catalogue numbers)*

The object of the declaration described above is in conformity with the relevant UK Statutory Instruments (and their amendments):

2016 No. 1101	*Electrical Equipment (Safety) Regulations (LV)*
2012 No. 3032	*Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations (RoHS)*

References to the relevant designated standards used or references to the other technical specifications in relation to which conformity is declared:

EN IEC 60947-4-1:2019+AC:2020-05	*Low-voltage switchgear and controlgear – Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters*
EN IEC 63000:2018	*Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances*

Signed for and on behalf of the above named manufacturer:

Place and date of issue:	*Milwaukee, WI USA 02-Nov-2026*
Name, function:	*Jandrew Gonzales, Manager., Global Product Certification – TS&C*
Signature:	

Catalogue number	*Series* [1]	*Description*	*Statutory Instrument* [2]		
			LV	*EMC*	*RoHS*
CAT8N-5.5P-240VAC		*Enclosed IEC Direct-On-Line Contactor – 240VAC Coil with On/Off Pushbutton*	*Yes*	*N/R*	*Yes*
CAT8N-5.5P-415VAC		*Enclosed IEC Direct-On-Line Contactor – 415VAC Coil with On/Off Pushbutton*	*Yes*	*N/R*	*Yes*
CAT8N-5.5R-240VAC		*Enclosed IEC Direct-On-Line Contactor – 240VAC Coil with Reset Pushbutton*	*Yes*	*N/R*	*Yes*
CAT8N-5.5R-415VAC		*Enclosed IEC Direct-On-Line Contactor – 415VAC with Reset Pushbutton*	*Yes*	*N/R*	*Yes*

1) Products of the series level indicated, as well as succeeding series levels, are certified. If no series letter or number is given, then all series are certified.

2) No = Product is not certified to this Statutory Instrument.
Yes = Product is certified to this Statutory Instrument.
N/R = This Statutory Instrument is not required for this product.

NOMENCLATURE:

Enclosed IEC Direct-On-Line Contactors based on the Catalogue Number Explanation

CAT8N	-	5.5	P	-	240VAC
1		2	3		4

1	*CAT8N*	*Base Catalogue Number* *Enclosed IEC Direct-On-Line CA8 Contactor*
2	*5.5*	*Contactor Size* *5.5kW contactor (12A)*
3	*P* *R*	*Pushbutton Type* *On/Off Pushbuttons* *Reset Pushbutton*
4	*240* *415*	*Coil Voltage* *240 VAC Coil* *415VAC Coil*